

REGARDING SAFE DRINKING WATER

Certificate

No. 117

DATE 03/06/2025

It is certified that an inspection team headed by— *Mr. Jai Kishan Kumar*
(Assistant Chemist) from *P. H. Division Bhagalpur West, Bhagalpur*
inspected the *Divine Happy_School, Warsaliganj, Chatrapati Talab*
Road, Mirjanhat, Bhagalpur on *31.05.2025* and found the *Divine*
Happy_School, Warsaliganj, Chatrapati Talab Road, Mirjanhat,
Bhagalpur has safe drinking water facilities for the students and members of staff
institution as per the norms prescribed by the Central/State/ U.T Govt.

The above valid for a period of- *One Year (03.06.2025 to 02.06.2026)*.

Signature With Seal:-

Kumar
03/06/25

Name

:- Sanjay Kr Paswan

Designation

:- Assistant Research Officer



To,
Divine Happy_School,
Chatrapati Talab Road, Mirjanhat,
Bhagalpur
Bihar
812005

Government Of Bihar

Regional Water Testing Laboratory

Public Health Engineering Department,

Bhagalpur

Name of School :- Divine Happy School

Sample Collected By- Lab Staff

Source of Sample- R.O Water

Ref.No. EE-1681 Dt-29/05/2025

Date of Sampling - 31.05.2025

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No.	Location			Physico - Chemical and Bacteriological Parameters													Remarks				
	Block	Panchayat	Village	Habitat	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃		SO ₄	F	As	Microbial
1					Divine Happy School Warsaliganj, Chatrapati Talab Road, Mirjanhat, Bhagalpur-812005	7.30	0.72	415.0	207.0	103.5	46.4	20.0	41.4	91.4	0.11	3.4	6.8	0.19	NA	Negative	
					Desirable Limit*	6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-	
					Permissible Limit* in absence of alternate source	NR	5.0	-	2000	600	200	100	1000	500	NR	NR	400	1.5	NR	**	

NA=Not Applicable

Memo No.... RL-117

Date 03/05/2025

Copy Forwarded To : I. Executive Engineer, P.H.Division Bhagalpur West, for kind information and necessary action.

Sumax
03/06/25
Lab Incharge(A.R.O)