REGARDING SAFE DRINKING WATER

Certificate

No. 93 **DATE** 12/06/2026

It is certified that an inspection team headed by– **Mr. Jai Kishan Kumar** **(Assistant Chemist)** *from* **P. H. Division Bhagalpur East. Bhagalpur** *inspected the* **Divine Happy_School, Chatrapati Talab Road, Mirjanhat, Bhagalpur** *on* **10.06.2026** *and found the* **Divine Happy_School ,Chatrapati Talab Road,Mirjanhat, Bhagalpur** *has safe drinking water facilities for the students and members of staff institution as per the norms prescribed by the Central/State/ U.T Govt.*

The above valid for a period of- ***One Year (12.06.2026 to 11.06.2027)***.

Kumar

Signature With Seal:- ----12/06/26

Name :- Sanjay Kr Paswan

Designation :-Assistant Research Officer

REGIONAL WATER TESTING LABORATORY * BHAGALPUR *

To,
Divine Happy_School,
Chatrapati Talab Road,Mirjanhat,
Bhagalpur
Bihar-812005

Government Of Bihar

Regional Water Testing Laboratory

Public Health Engineering Department,

Bhagalpur

Ref.No. EE-1555 Dt- 08.06.2026

Date of Sampling - 10.06.2026

Name of School :- **Divine Happy School**

Sample Collected By- Lab Staff

Source of Sample- Raw water

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No.	Location					Physico - Chemical and Bacteriological Parameters														Remarks
	Block	Panchayat	Village	Habitation	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO_3	SO_4	F	As	Microbial	
1	**Divine Happy School Chatrapati Talab Road, Mirjanhat,Bhagalpur-812005**					7.38	0.96	568.0	284.0	144.8	57.9	19.31	132.8	69.1	0.23	4.48	9.1	0.16	NA	Negative	
	Desirable Limit*					6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-	
	Permissible Limit* in absence of alternate source					NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**	

NA=Not Applicable

Memo No....RL-93

Date 12/06/2026

Copy Forwarded To :1. Executive Engineer, P.H.Division Bhagalpur West, for kind information and necessary action.

Kumar
12/06/26
Lab Incharge(A.R.O)