

## REGARDING SAFE DRINKING WATER

### Certificate

No. RL-146

DATE 01/07/2024

It is certified that an inspection team headed by— *Mr. Sanjay Kumar Paswan* (A.R.O) from *P. H. Division Bhagalpur West, Bhagalpur* inspected the *Divine Happy\_School, Chatrapati Talab Road, Mirjanhat, Bhagalpur* on *24.06.2024* and found the *Divine Happy\_School, Chatrapati Talab Road, Mirjanhat, Bhagalpur* has safe drinking water facilities for the students and members of staff institution as per the norms prescribed by the Central/State/ U.T Govt.

The above valid for a period of- *One Year (01.07.2024 to 30.06.20 25)*.

Signature With Seal: \_\_\_\_\_

Name \_\_\_\_\_

Designation \_\_\_\_\_

*Sanjay Kumar*  
*01/07/24*

To,  
*Divine Happy\_School,*  
*Chatrapati Talab Road, Mirjanhat,*  
*Bhagalpur*  
*Bihar*  
*812005*





# Regional Water Testing Laboratory

Public Health Engineering Department,

Bhagalpur

Name of School :- Divine Happy School

Sample Collected By- Lab Staff

Source of Sample- Raw water

Ref.No. EE-1522 Dt-10/06/2024

Date of Sampling - 24.06.2024

## PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No.	Location				Physico - Chemical and Bacteriological Parameters														Remarks		
	Block	Panchayet	Village	Habitation	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F		As	Microbial
1	Divine Happy School Chatrapati Talab Road, Mirjanhat, Bhagalpur- 812005					7.13	0.73	774.0	387.0	197.6	43.3	27.5	48.6	176.2	0.20	4.1	7.5	0.42	NA	Negative	
	Desirable Limit**				6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-		
	Permissible Limit* in absence of alternate source				NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**		

NA=Not Applicable

Memo No.... RL-146

Date .... 01/07/2024

Copy Forwarded To : J. Executive Engineer, P.H.Division Bhagalpur West, for kind information and necessary action.

*Stomax*  
01/07/24  
Lab Incharge(A.R.O)